

STATE OF TEXAS WELL REPORT for Tracking #67622

Owner: Maybell Freitag	Owner Well #: No Data
Address: 301 CR 224 Eldorado, TX 76936	Grid #: 55-13-1
Well Location: 301 CR 224 Eldorado, TX 76936	Latitude: 30° 50' 21" N
Well County: Schleicher	Longitude: 100° 28' 50" W
	Elevation: No Data
Type of Work: New Well	
	Proposed Use: Domestic

Drilling Start Date: **5/3/2005** Drilling End Date: **5/5/2005**

	<i>Diameter (in.)</i>	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>
Borehole:	9.5	0	4
	7.875	4	308

Drilling Method: **Air Rotary**

Borehole Completion: **Straight Wall**

	<i>Top Depth (ft.)</i>	<i>Bottom Depth (ft.)</i>	<i>Description (number of sacks & material)</i>
Annular Seal Data:	1	21	4 Cement

Seal Method: **Poured**

Sealed By: **Driller**

Distance to Property Line (ft.): **100**

Distance to Septic Field or other concentrated contamination (ft.): **300**

Distance to Septic Tank (ft.): **No Data**

Method of Verification: **No Data**

Surface Completion: **Pitless Adapter Used**

Water Level: **210 ft.** below land surface on **2005-05-05** Measurement Method: **Unknown**

Packers: **No Data**

Type of Pump: **Submersible**

Well Tests: **Estimated** Yield: **40 GPM**

Water Quality:	<i>Strata Depth (ft.)</i>	<i>Water Type</i>
	277	Fresh

Chemical Analysis Made: **No**

Did the driller knowingly penetrate any strata which contained injurious constituents?: **No**

Certification Data: The driller certified that the driller drilled this well (or the well was drilled under the driller's direct supervision) and that each and all of the statements herein are true and correct. The driller understood that failure to complete the required items will result in the report(s) being returned for completion and resubmittal.

Company Information: **Abel Water Systems**
PO Box 348
San Angelo, TX 76902

Driller Name: **Clark Abel** License Number: **2972**

Comments: **No Data**

Lithology:
 DESCRIPTION & COLOR OF FORMATION MATERIAL

Casing:
 BLANK PIPE & WELL SCREEN DATA

<i>From (ft)</i>	<i>To (ft)</i>	<i>Description</i>
0	1	Top Soil
1	4	Rock
4	7	Caliche
7	193	White Limestone
193	231	Gray Limestone
231	277	White Limestone
277	295	Broken Limestone-water
295	308	Limestone

<i>Dia. (in.)</i>	<i>New/Used</i>	<i>Type</i>	<i>Setting From/To (ft.)</i>
5"	New	PVC slotted	308 to 268 .035
5"	New	PVC solid	268 to -2
5"	New	Steel	-2 to +2

IMPORTANT NOTICE FOR PERSONS HAVING WELLS DRILLED CONCERNING CONFIDENTIALITY

TEX. OCC. CODE Title 12, Chapter 1901.251, authorizes the owner (owner or the person for whom the well was drilled) to keep information in Well Reports confidential. The Department shall hold the contents of the well log confidential and not a matter of public record if it receives, by certified mail, a written request to do so from the owner.

Please include the report's Tracking Number on your written request.

Texas Department of Licensing and Regulation
P.O. Box 12157
Austin, TX 78711
(512) 334-5540